



● manta



Typ svítidla / Lighting type		
Označení	Obj. kód	LxWxH (mm)
Manta 1x28/54 W		
M12017-128L-93	380401	1200x170x50
M12017-128M-93	381401	
M12017-154L-93	380501	
M12017-154M-93	381501	
Manta 1x35/49/80 W		
M15017-135L-93	380601	1500x170x50
M15017-135M-93	381601	
M15017-149L-93	380701	
M15017-149M-93	381701	



Popis

Použití: Svítidla jsou díky výborným optickým vlastnostem vhodná pro osvětlení interiérů například administrativních budov, obchodů, bank, atd.

Tělesa svítidel jsou z ocelového plechu lakovaná práškovou barvou v odstínu RAL 9006, RAL 9003. Nebo jinou RAL.

Optické mřížky se nabízí ve dvou variantách - z vysoce leštěného hliníkového plechu
- z matného hliníkového plechu.

Elektrická výzbroj svítidel je tvořena standardně el.předřadníkem, objímkami G5.

Montáž svítidel lze provádět přímo na strop nebo za použití lankových závěsů svítidla zavěsit.

Závěsná svítidla vyrábíme ve variantě k přímému osvětlení či přímo-nepřímému osvětlení. Závěsná svítidla P/N jsou opatřena otvory ve vrchní části svítidla, které propuští část světla a svítidlo pak osvětluje i horní prostor (strop).

Description

Usage: the lighting units are in particular designated for the use in administrative complexes, schools, shopping centres, representative areas, banks or offices.

Body of the lighting unit: steel plate varnished by pulverized paint, tone RAL 9006, RAL 9003.

Optical louvres are offered in two basic variations - made of anodised highly polished aluminium
- made of anodised matt aluminium.

Electrical accessories consist of electronic ballasts, 3-pole push wire terminals for connection of conductors up to 2,5mm² and G5 lamp, holdres. Internal wiring is done using 0,5mm² conductors. Emergency power source up to 3 hours is available on request.

Installation: lighting units can be mounted directly to the ceiling or suspended using our string hangers. By suspended instalation, there is a possibility to use direct-indirect illumination (marked P/N). It is achieved by holes at the top of the lighting body, which transmit amount of light, so that ceiling is illuminated as well. The indirect illumination has got pleasant and easthetically positive impact, especially for the representative areas.

Další info

